

Monthly Inspection

Cell: 519-661-8526 | Email: service@genchek.ca | web: www.genchek.ca

Generator Make:	_Model:	Serial:
Consumables		Control panel settings
Fuel level		Test remote signals
Oil level		Air control louvers
Coolant level		Test emergency lighting unit(s)
Leakage		Generator room temp above 10 C
Fuel transfer pump		Room cleanliness
Starter System	Te	st Entire System
Electric starter		Simulate a power failure
Air starter		Verify batt. charger current output
Battery/Charger Equipment		increases while cranking
Electrolyte fill level		Operate all ATS's
Test electrolyte S.G.		Brush operation for sparking
Electrical connections		Bearing seal leakage
Battery cleanliness		Auxiliary equipment
Test charger		Operate system for 60 minutes
Charger electrical connect	ions	Drain exhaust system
Engine	Sy	stem Notes
Test heaters		Time On
Governor control		Verify volts are normal
Fuel pump oil sump		Verify amps are normal
Fan belts		Verify frequency is normal
Heater hoses/wires		Verify oil pressure is normal
Control Panel		Verify water itemp. is normal
Control panel covers		Time Off
Test annunciator lamps		Put system back in Auto
Comments:		
01		Data